



<http://stores.ebay.com/UsefulCDs>

DATE Feb 14, 1975
page 1 **of** 1

SUBJECT: PRODUCT IMPROVEMENTS AND
SPEC ADVANCE

REF. FILE# S-34

MODEL(S) or SERIES:

EFFECTIVE: SPEC "G".

6.ONH-1R/9000 GENERATOR SETS

The following changes effective February 13, 1975 are being made on the above model:

1. New circuit breaker part #320-0549.
2. Addition of a guard to the Vacu-Flo scroll.
3. Change in crankshaft blower wheel keyway.
4. AC output leads changed from 3 to 2.
5. Changed starter (new part #191-1052).

The circuit breaker (Item #1) was changed because of a nuisance tripping problem on some models-(due to vibration).

On units prior to Spec "G", a new Kit is available, part #320-0570, which contains all necessary parts and installation instructions to install the new circuit breaker.

This is not a mandatory field modification.

This bulletin is for informational purposes.